

Corrigendum for the quotation call notice vide No. NLUO/ACAD/12543/18 dated on 21/12/2018 for LT cable laying to carried out at NLUO, cuttack following enquiry were requested by the bidders.

SL no.	Clarification Asked	Clarification replied
1.	Request for full specification of the cable.	PVC insulated and PVC sheathed /XLPE armoured aluminium power cable of 300sqmm and 3.5core of 1.1KV grade.
2.	Type of cable laying	Over the ground with Iron clamps to be fastened in the concrete without brick/sand/stone.

* This corrigendum is to be attached with the tender paper with duly stamped & signed.