

Corrigendum for the quotation call notice vide No. NLUO/ACAD/12543/18 dated on 21/12/2018 for Regular maintenance (Electrical) to carried out at NLUO, cuttack following enquiry were requested by the bidders.

SL no.	Clarification Asked	Clarification replied
1.	Item no. 1 led bulb specification	9W of led bulb
2.	Item no. 7 Rewinding of ceiling fan inclusive of which rates.	Rewinding of ceiling fan including bearings and 2.5uF capacitor.
3.	Item no. 8 Geyser capacity & mode of repair	Geyser of 15L capacity and to repair existing defect of any kind.

* This corrigendum is to be attached with the tender paper with duly stamped & signed.